



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 10/20/2020
Received: 10/16/2020
Sampled By:
Work Order: 0290051

C **Tooley Water District**
L Attn: Matt Olson
I PO Box 699
E Newberg OR, 97132
N Phone: (503) 537-4504
T

Project: Tooley Water District
Project # : N/A
PWSID # : 4100911

Sampling Location: EP-A Well #2 (Lower)
Sample Matrix: Drinking Water

Lab Number

	Code	Method	Units	Result	MRL	EPA MCL	Analysis Date/ Time
0290051-01	Sample Name: Nitrate-Lower Well						
	Sampled: 10/16/20 9:55						
<i>Inorganics</i>							
A Nitrate as N	1040	SM4500-NO3 D	mg/L	18.6	1.0	10	10/16/20 18:00 MCLE

MCLE This analyte exceeds the MCL limit.

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit

A = All procedures for this analysis are accredited in accordance with NELAP standards. Lab Accreditation No. OR-100013

Approved by: 
Adriana Gonzalez-Gray
Laboratory Director

This report shall not be reproduced, except in full, without the written approval of the laboratory.