



Nitrate Form

City of The Dalles Water Quality Lab 6780 Reservoir Road The Dalles Oregon 97058 Phone:541-298-2248

ORELAP #100002

To be Filled in by Person Submitting Sample	
Public Water System: <u>Tooley Water District</u>	Report test results to OHA? <u>yes</u>
PWS ID #: <u>4100911</u>	Source ID: <u>AA</u> Source name: <u>well 1 Upper well</u>
Physical Address:	Mailing Address:
<u>9730 Highway 30 w</u>	<u>Same</u>
<u>The Dalles 97058</u>	
Phone: <u>541-993-9279</u>	Email: <u>gorgemusic@yahoo.com</u>
Sampled at: <u>Reservoir</u>	Sampled by: <u>Larry Russ</u>
Date Collected: <u>10-22-20</u>	Time collected: <u>12:15</u>
Sample Composition: Raw or <u>Treated Water</u> From Source or <u>Distribution</u> <u>Single</u> or Combined Sample	

Delivered By: <u>Larry Russ</u>	Date: <u>10-22-20</u>	POSTED
---------------------------------	-----------------------	---------------

To be Completed by Laboratory					
Date received in lab: <u>10-22-20</u> ^{12:47 PM}	Date analyzed: <u>10-22-2020</u>	Temperature: <u>20</u> Evidence cooling? <u>Yes</u> No			
Lab sampled ID #: <u>206313</u>	Sample composited in lab: No				
Contaminant	Code	MCL mg/l	Analysis mg/l	Method	Analyst
Nitrate	1805	10.	9.36	HACH 10206	Romas

Comments

ND = "Not Detected" at the labs minimum reporting limit.

MDL= 1.0 ppm

The results in this report apply to the sample analyzed and identified with the unique identifier of the lab sample ID # and only to that sample. This analytical report shall not be reproduced except in full without the written approval of the laboratory.

Reported By: [Signature]

Date: 10-22-20

Reviewed By: [Signature] Date: 10-22-20