



ORELAP #100002

To be Filled in by Person Submitting Sample	
Public Water System <u>Tooley Water District</u>	Report test results to OHA? <u>yes</u>
PWS ID #: <u>4100911</u>	Source ID: <u>AA upperwell</u> Source name: <u>Taken at Reservoir</u>
Physical Address:	Mailing Address:
<u>4730 Highway 30 West</u>	<u>Same</u>
Phone: <u>541-993-9279</u>	Email: <u>gorge music@yahoo.com</u>
Sampled at: <u>Reservoir</u>	Sampled by: <u>Harvy Russ</u>
Date Collected: <u>10-28-20</u>	Time collected: <u>11:45 AM</u>
Sample Composition: Raw or <u>(Treated Water)</u> From Source or <u>(Distribution)</u> <u>(Single or Combined Sample)</u>	

Delivered By: <u>Harvy Russ</u>	Date: <u>10-28-2020</u>
----------------------------------------	--------------------------------

To be Completed by Laboratory					
Date received in lab: <u>12:17 PM 10-28-2020</u>	Date analyzed: <u>10-29-20</u>	Temperature: <u>16°C</u> Evidence cooling? <u>(Yes)</u> No			
Lab sampled ID #: <u>206332</u>	Sample composited in lab: No				
Contaminant	Code	MCL mg/l	Analysis mg/l	Method	Analyst
Nitrate	1805	10.	2.61	HACH 10206	Miller

Comments

ND = "Not Detected" at the labs minimum reporting limit.
 MDL= 1.0 ppm
 The results in this report apply to the sample analyzed and identified with the unique identifier of the lab sample ID # and only to that sample.
 This analytical report shall not be reproduced except in full without the written approval of the laboratory.

[Signature] _____ 10-30-20 _____
 Reported By Date

Reviewed By: Ramos Date: 10-29-2020