



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

# ANALYSIS REPORT

Reported: 02/19/2021  
Received: 02/10/2021  
Sampled By: David Criss  
Work Order: 1042001

**C** **Tooley Water District**  
**L** Attn: Matt Olson  
**I** PO Box 699  
**E** Newberg OR, 97132  
**N** Phone: (503) 537-4504  
**T**

**Project:** Tooley Water District  
Project # : N/A  
PWSID # : 4100911

Sampling Location: EP-B lower well  
Sample Matrix: Drinking Water

## Lab Number

Code	Method	Units	Result	MRL	EPA MCL	Analysis Date/ Time
<b>1042001-01</b>	<b>Sample Name:</b> Nitrate <b>Sampled:</b> 2/10/21 11:25					
<i>Inorganics</i>						
A	Nitrate as N	1040 SM4500-NO3 D	mg/L	8.9	0.5 10	02/11/21 15:45

**ND** = None detected at the MRL    **MRL** = Minimum Reporting Limit    **MCL** = Maximum Contamination Limit  
**A** = All procedures for this analysis are accredited in accordance with NELAP standards. Lab Accreditation No. OR-100013

Approved by:   
Adriana Gonzalez-Gray  
Laboratory Director

*This report shall not be reproduced, except in full, without the written approval of the laboratory.*