



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 10/18/2021
Received: 10/08/2021
Sampled By: Mel
Work Order: 1281003

C L I E N T **Tooley Water District**

Attn: Matt Olson
PO Box 699
Newberg OR, 97132
Phone: (503) 537-4504

Project: Tooley Water District

Project # : N/A

PWSID # : 4100911

Sampling Location: EP-B lower well

Sample Matrix: Drinking Water

Lab Number

	Code	Method	Units	Result	MRL	EPA MCL	Analysis Date/ Time
1281003-01	Sample Name: Nitrate						
	Sampled: 10/7/21 15:50						
<i>Inorganics</i>							
A Nitrate as N	1040	SM4500-NO3 D	mg/L	5.4	0.5	10	10/08/21 17:00


ND = None detected at the MRL

MRL = Minimum Reporting Limit

MCL = Maximum Contamination Limit

A = All procedures for this analysis are accredited in accordance with NELAP standards. Lab Accreditation No. OR-100013

Approved by: _____


Adriana Gonzalez-Gray
Laboratory Director

This report shall not be reproduced, except in full, without the written approval of the laboratory.