



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**

Reported: 03/08/2022  
Received: 03/02/2022  
Sampled By: Tracey  
Work Order: 2061015

**C** **Tooley Water District**  
**L** Attn: Matt Olson  
**I** PO Box 699  
**E** Newberg OR, 97132  
**N** Phone: (503) 537-4504  
**T**

**Project:** Tooley Water District  
**Project # :** N/A  
**PWSID # :** 4100911

**Sampling Location:** EP-B Lower Well  
**Sample Matrix:** Drinking Water

**Lab Number**

	Code	Method	Units	Result	MRL	EPA MCL	Analysis Date/ Time
<b>2061015-01</b>	<b>Sample Name:</b> Nitrate <b>Sampled:</b> 3/2/22 8:45						
<b>Inorganics</b>							
A Nitrate as N	1040	EPA 300.0	mg/L	5.97	0.100	10	03/02/22 16:17

**ND** = None detected at the MRL    **MRL** = Minimum Reporting Limit    **MCL** = Maximum Contamination Limit  
**A** = All procedures for this analysis are accredited in accordance with NELAP standards. Lab Accreditation No. OR-100013

Approved by:   
Adriana Gonzalez-Gray  
Laboratory Director