



Professional Laboratory Services

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 03/17/2022
Received: 03/16/2022
Sampled By: Tracey
Work Order: 2075058

C Tooley Water District
L Attn: Matt Olson
I PO Box 699
E Newberg OR, 97132
N Phone: (503) 537-4504
T

Project: Tooley Water District
Project #: N/A
PWSID #: 4100911

Sampling Location: EP-B Lower Well
Sample Matrix: Drinking Water

Lab Number

Table with 8 columns: Code, Method, Units, Result, MRL, EPA MCL, Analysis Date/ Time. Row 1: 2075058-01, Sample Name: Nitrate, Sampled: 3/16/22 9:55. Row 2: Inorganics. Row 3: A Nitrate as N, 1040, EPA 300.0, mg/L, 16.2, 0.100, 10, 03/16/22 17:48 MCLE

MCLE This analyte exceeds the MCL limit.

ND = None detected at the MRL MRL = Minimum Reporting Limit MCL = Maximum Contamination Limit

A = All procedures for this analysis are accredited in accordance with NELAP standards. Lab Accreditation No. OR-100013

Approved by: [Signature]
Adriana Gonzalez-Gray
Laboratory Director

This report shall not be reproduced, except in full, without the written approval of the laboratory.