



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 05/10/2022
Received: 04/28/2022
Sampled By: Tracey
Work Order: 2118003

C **Tooley Water District**
L Attn: Matt Olson
I PO Box 699
E Newberg OR, 97132
N Phone: (503) 537-4504
T

Project: Tooley Water District
Project # : N/A
PWSID # : 4100911

Sampling Location: EP-B Well #2 (Lower)
Sample Matrix: Drinking Water

Lab Number

| | Code | Method | Units | Result | MRL | EPA MCL | Analysis Date/ Time |
|-------------------|--|--------------|-------|--------|-----|---------|---------------------|
| 2118003-01 | Sample Name: Nitrate Sampled: 4/27/22 15:05 | | | | | | |
| <i>Inorganics</i> | | | | | | | |
| A Nitrate as N | 1040 | SM4500-NO3 D | mg/L | 8.4 | 0.5 | 10 | 04/29/22 11:30 |

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit
A = All procedures for this analysis are accredited in accordance with NELAP standards. Lab Accreditation No. OR-100013

Approved by: 
Adriana Gonzalez-Gray
Laboratory Director

This report shall not be reproduced, except in full, without the written approval of the laboratory.