



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 06/09/2022
Received: 05/25/2022
Sampled By:
Work Order: 2145056

C **Tooley Water District**
L Attn: Matt Olson
I PO Box 699
E Newberg OR, 97132
N Phone: (503) 537-4504
T

Project: Tooley Water District
Project # : N/A
PWSID # : 4100911

Sampling Location: EP-B Well #2 (Lower)
Sample Matrix: Drinking Water

Lab Number

	Code	Method	Units	Result	MRL	EPA MCL	Analysis Date/ Time
2145056-01	Sample Name: Nitrate Sampled: 5/25/22 11:45						
<i>Inorganics</i>							
A Nitrate as N	1040	EPA 300.0	mg/L	ND	0.100	10	05/25/22 19:08

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit
A = All procedures for this analysis are accredited in accordance with NELAP standards. Lab Accreditation No. OR-100013

Approved by: 
Adriana Gonzalez-Gray
Laboratory Director

This report shall not be reproduced, except in full, without the written approval of the laboratory.