



Professional Laboratory Services

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 08/19/2022
Received: 08/17/2022
Sampled By: Tracey
Work Order: 2229003

CLIENT
Tooley Water District
Attn: Matt Olson
PO Box 699
Newberg OR, 97132
Phone: (503) 537-4504

Project: Tooley Water District
Project #: N/A
PWSID #: 4100911

Sampling Location: EP-B Well #2 (Lower)
Sample Matrix: Drinking Water

Lab Number

Table with 7 columns: Code, Method, Units, Result, MRL, EPA MCL, Analysis Date/ Time. Row 1: 2229003-01, Sample Name: Nitrate, Sampled: 8/16/22 11:48, Inorganics, A Nitrate as N, 1040, EPA 300.0, mg/L, 11.7, 0.100, 10, 08/17/22 15:09 MCLE

MCLE This analyte exceeds the MCL limit.

ND = None detected at the MRL MRL = Minimum Reporting Limit MCL = Maximum Contamination Limit

A = All procedures for this analysis are accredited in accordance with NELAP standards. Lab Accreditation No. OR-100013

Approved by: [Signature]
Adriana Gonzalez-Gray
Laboratory Director

This report shall not be reproduced, except in full, without the written approval of the laboratory.